



Corrective Enforcement Summary Report

Today's Date: Feb 13 2023 Building Permit No. 20140566
Issued: April 11, 1997 Expired: Dec. 21, 2016
Description of Project: SWM on foundation
Last Approved Inspection: December 9 / 2010
Bylaw Enforcement Officer: Rick Cunningham

File Summary:

- Permit expired in 2016
- No Progress in last 7 years.
- Multiple Permit renewal letters sent
- Owner has stated that he has no plans to bring file into compliance

Action Required:

- ☐ Continue with Bylaw Enforcement
☒ Recommend for Notice on Title

[Redacted Signature]

Feb 13 / 2023

Virgil Hoefels
Chief Building Official

CORRECTIVE ENFORCEMENT ACTION CHECKLIST

Permit # 2014 0566

Expired: 12/21/2016.

Owner(s): [REDACTED]

Was issued in 1997

Date	Inspection	Status (pass/fail)	Action
Apr. 15/1997 May 12/1997	FOOTING FORMS	fail pass	
May 20/1997	FOUNDATION FORMS	pass	
	ROUGH-IN FOR RADON		
May 23/1997	PRE-BACKFILL	pass	
Aug 14/07	FRAMING	fail	
	U/SLAB PLUMBING		
Aug 14/07	R/IN PLUMBING	fail	
	WOOD APPLIANCE/CHIMNEY		
Aug 14/07	INSULATION	fail	
Dec 9/2010	COMPLETION/FINAL	fail	Deficiencies of Aug 14/07 Remain eng'd design required for wood cross beams.
	EXPIRED PRIORITY LEVEL		Steel frame supporting unit not supported at ends.