

RUSSET BLUFF WATER SYSTEM 2024 ANNUAL REPORT

Operating Permit # 002914 CRD Utilities Department

building communities together

File: 5600-20-06-01

January 14, 2025

Christine Sweezey
Environmental Health Officer
Interior Health
540 Borland Street, 3rd Floor
Williams Lake, BC V2G 2G8

Dear Christine Sweezey:

Re: Transmittal of the 2024 Annual Report for the Russet Bluff Water System

We are pleased to submit the 2024 Annual Report for the Russet Bluff Water System. This report is prepared to provide a comprehensive summary of the key developments, activities, and achievements of 2024, as well as to outline plans for the water system.

The report has been developed with consideration for public engagement and transparency, ensuring it meets the information needs of Interior Health, the Cariboo Regional District Board of Directors, and particularly the Russet Bluff community, as represented by Electoral Area E Director Melynda Neufeld.

We trust this report will serve as a valuable resource in understanding the progress and direction of the Russet Bluff Water System.

Sincerely,

Kelly McDonald
Manager of Utilities

KM/cm

building communities together

Contents

1. Executive Summary	1
1.1. Key Information	1
2. Introduction	1
3. Maintenance	1
4. Projects and Planned Activities	2
5. Environmental Operator’s Certification Program (EOCP)	2
6. Source to Tap Risks and Cross-Connection Control	3
7. Water Sampling	3
8. Water Quality	3
9. Events	3
9.1. Asset Management	3
9.2. Water Demand	3
10. Emergency Planning	4
10.1. Key Elements of the ERCP	4
11. Conclusion	4
12. References	5
Appendix A: Links	6
Appendix B: Sample Results	8
Appendix C: Emergency Plans	22

Tables and Figures

Table 1: Environmental Operator Certification Levels	2
--	---

1. Executive Summary

The Russet Bluff Water System, operated by the Cariboo Regional District (CRD) since 2008, serves approximately 250 residents with 3.8 km of distribution piping originally constructed with asbestos cement. To manage water quality concerns, particularly the extreme hardness observed in the Lower Well, operations now rely solely on the Upper Well, successfully eliminating previous water quality advisories. CRD Operators adhere to a strict maintenance and sampling schedule—comprising weekly inspections, regular bacteriological testing, and comprehensive chemical analyses—to ensure consistent water quality and system reliability. Looking ahead, a 2025 system Master Plan is set to enhance asset management and long-term budgeting, while planned upgrades, including a flowmeter installation, aim to improve water demand monitoring. In addition, continued progress in the Environmental Operator’s Certification Program and the development of an Emergency Response and Contingency Plan underscore CRD’s commitment to safeguarding public health and ensuring prompt responses to potential emergencies.

1.1. **Key Information:**

System key facts:

- 3.8 km of PVC pipe
- Single reservoir
- 2 wells
- 2 pumpstations
- 100 service connections serving approximately 250 residents
- Untreated

2. Introduction

The Russet Bluff Water System has been operated by the CRD since 2008 (*Russet Bluff Water System Service Establishment Bylaw No. 4407, 2008*). The system was previously constructed and operated by *Fetters Development Ltd*. The Russet Bluff Water System serves approximately 250 residents by way of 3.8 km of distribution piping. The system was originally installed using asbestos cement pipe (AC), which makes up 3 km of the existing mainline, and has a lower estimated lifespan than other pipe materials such as polyvinyl chloride (PVC) and steel.

3. Maintenance

CRD Operators follow a structured maintenance and monitoring schedule approved by

Interior Health Authority to ensure water quality. Key activities include:

- Collecting 48 bacteriological water samples annually and sending them to an accredited laboratory to confirm potability and detect potential issues.
- Conducting full-spectrum water quality analysis as required.
- Performing weekly inspections and maintenance of system equipment to monitor performance and ensure operational reliability.

4. Projects and Planned Activities

The commissioning of a system Master Plan for Russet Bluff is budgeted for 2025 to assist in asset management and long-term cost analysis. This plan will consider such factors as expected lifespan and criticality of assets to best prioritize spending.

5. Environmental Operator’s Certification Program (EOCP)

The CRD has been active in 2024, with staff completing numerous training courses and achieving certification levels in the Environmental Operator’s Certification Program (EOCP). The Central region systems have two certified Operators (*table 1*).

The Operators are responsible for operating the Russet Bluff Water System along with Russet Bluff and Russet Bluff water systems. These Operators are also responsible for the sewer systems in Russet Bluff, Pine Valley and Wildwood.

Table 1: Environmental Operator Certification Levels

<u>Operator</u>	<u>Region</u>	<u>Water Distribution</u>	<u>Water Treatment</u>	<u>Small Water Systems</u>
Ken Heidema	Central	2	1	<input checked="" type="checkbox"/>
Charles Howes	Central	1	1	
<i>Jourdy Ouellette (backup)</i>	<i>South</i>	3	2	
<i>Philip Wilkins (backup)</i>	<i>North</i>	1	1	<input checked="" type="checkbox"/>
<i>Manager (backup)</i>	<i>Central</i>	4	1	

Operators have worked diligently to maintain the level of service our residents expect while safeguarding public health. We anticipate improvements in 2025 through additional staff and continued training.

6. Source to Tap Risks and Cross-Connection Control

The Russet Bluff Water System relies on two source wells located in a developed area at the center of the community, which poses a higher risk of contamination due to nearby human activities. To mitigate these risks, establishing a Source Protection Area will be assessed.

7. Water Sampling

The 2024 sampling schedule consisted of a full chemical analysis as well as twice monthly bacteriological sampling at two locations.

** Sample results attached.*

8. Water Quality

The source groundwater is extremely hard, particularly in the Lower Well. The Russet Bluff Upper Well has a hardness of over 600*, the Lower Well 1170* hardness (*over 200* is considered very hard water*). We have since tested and found we are keeping up with summer demand utilizing only the Upper Well. By not using the Lower Well, we were able to rescind the water quality advisories that were previously on the system.

** mg/L as CaCO₃*

9. Events

9.1. Asset Management

Throughout 2024, asset management inventory and implementation efforts have been ongoing across all Cariboo Regional District utilities, including the Russet Bluff Water System. This initiative is designed to support more efficient budgeting for system improvements and strengthen preventive maintenance practices. A system Master Plan is scheduled for development in 2025 to assist with long-term budgeting and improve eligibility for grant funding opportunities.

9.2. Water Demand

Currently, water demand is measured by pump hours as the system has no flowmeter. This method is very unreliable and plans for a flowmeter installation are necessary.

10. Emergency Planning

A new Emergency Response and Contingency Plan (ERCP) for the Russet Bluff Water System is currently being developed to enhance preparedness and ensure quick, coordinated responses to potential emergencies affecting the water supply.

The process began with a risk assessment to identify potential hazards, such as equipment failures, natural disasters, contamination events, and power outages. Stakeholder input, including feedback from Operators, community members, and regulatory bodies, helped shape the plan to address specific vulnerabilities and local conditions.

10.1. Key Elements of the ERCP

The key elements of the ERCP include:

- Clear Response Protocols: Step-by-step actions for various emergency scenarios.
- Roles and Responsibilities: Defined roles for Operators, management, and external agencies.
- Communication Strategies: Procedures for notifying residents, government agencies, and media.
- Resource Allocation: Identification of equipment, backup systems, and personnel required during emergencies.
- Training and Drills: Regular exercises to ensure staff are familiar with the plan and can respond efficiently.

The plan will be reviewed and approved by local health authorities to ensure compliance with provincial regulations. Updating the ERCP ensures that emergency procedures align with the current operational capacity.

In addition, a drought management plan is also currently being developed in line with best practice.

** Plans attached.*

11. Conclusion

In conclusion, the Russet Bluff Water System continues to effectively serve its community by addressing aging infrastructure and water quality challenges through rigorous maintenance, targeted operational adjustments, and proactive planning. By relying solely on the Upper Well, the system has successfully eliminated previous water quality advisories, ensuring safe drinking water for approximately 250 residents. Future initiatives, including the development of a comprehensive Master Plan, flowmeter installation for improved water demand monitoring, and enhanced emergency response planning, reinforce the Cariboo Regional

District's commitment to sustainable operations and public health protection.

12. References

- *Health Canada (2019, May 21). Guidance on Natural Organic Matter in Drinking Water. Retrieved from <https://www.canada.ca/en/health-canada/programs/consultation-organic-matter-drinking-water/document.html#es>*
- *Environmental Operators Certification Program (2024). Retrieved from <https://eocp.ca/>*
- *Sample results, Interior Health. Retrieved from <https://services.interiorhealth.ca/publichealthprotection/watersamples.aspx>*
- *Statistics Canada (2021). Survey of Drinking Water Plants – The Daily. <https://www150.statcan.gc.ca/n1/daily-quotidien/231114/dq231114d-eng.htm>*

Thank you to:

- *Cheryl McMullen*
- *Jourdy Ouellette*
- *Colin Brusic*
- *Ken Heidema*
- *Chuck Howes*
- *Phil Wilkins*
- *Tyler Olsen*

for their contribution.

Appendix A: Links

Interior Health:

- [Interior Health Water Advisories](#)
- [Drinking Water | Environmental & Seasonal Health | IH](#)

Cariboo Regional District:

- [Water Notices and Advisories - Cariboo Regional District](#)
- [Sewer and Water Services - Cariboo Regional District](#)

Notification App (VoyentAlert!):

- [Emergency Notification System - Cariboo Regional District](#)

Environmental Operators Certification Program (EOCP):

- [EOCP Homepage | EOCP](#)
- [Backflow Prevention, Cross Connection Control, and the Environmental Operators Certification Program | EOCP](#)

Appendix B: Sample Results

2024 Russet Bluff Water System Annual Report

Facility and Sample Site: Russet Bluff Water System 2214 Grebe Drive, Williams Lake, BC	Test Type: Drinking Water – Bacteriological Unit of Measure: CFU per 100 ml	Value	Date Collected	Results
Pumphouse	Sample Parameter: E. coli Sample Parameter: Total Coliform	<1 <1	03 Jan 2024 03 Jan 2024	Acceptable Acceptable
Sample Station	Sample Parameter: E. coli Sample Parameter: Total Coliform	<1 <1	03 Jan 2024 03 Jan 2024	Acceptable Acceptable
Pumphouse	Sample Parameter: E. coli Sample Parameter: Total Coliform	<1 <1	09 Jan 2024 09 Jan 2024	Acceptable Acceptable
Sample Station	Sample Parameter: E. coli Sample Parameter: Total Coliform	<1 <1	09 Jan 2024 09 Jan 2024	Acceptable Acceptable
Pumphouse	Sample Parameter: E. coli Sample Parameter: Total Coliform	<1 <1	05 Feb 2024 05 Feb 2024	Acceptable Acceptable
Sample Station	Sample Parameter: E. coli Sample Parameter: Total Coliform	<1 <1	05 Feb 2024 05 Feb 2024	Acceptable Acceptable
Pumphouse	Sample Parameter: E. coli Sample Parameter: Total Coliform	<1 <1	12 Feb 2024 12 Feb 2024	Acceptable Acceptable
Sample Station	Sample Parameter: E. coli Sample Parameter: Total Coliform	<1 <1	12 Feb 2024 12 Feb 2024	Acceptable Acceptable
Pumphouse	Sample Parameter: E. coli Sample Parameter: Total Coliform	<1 <1	04 Mar 2024 04 Mar 2024	Acceptable Acceptable
Sample Station	Sample Parameter: E. coli Sample Parameter: Total Coliform	<1 <1	04 Mar 2024 04 Mar 2024	Acceptable Acceptable
Pumphouse	Sample Parameter: E. coli Sample Parameter: Total Coliform	<1 <1	11 Mar 2024 11 Mar 2024	Acceptable Acceptable
Sample Station	Sample Parameter: E. coli Sample Parameter: Total Coliform	<1 <1	11 Mar 2024 11 Mar 2024	Acceptable Acceptable
Sample Station	Sample Parameter: E. coli Sample Parameter: Total Coliform	<1 <1	03 Apr 2024 03 Apr 2024	Acceptable Acceptable
Sample Station	Sample Parameter: E. coli Sample Parameter: Total Coliform	<1 <1	09 Apr 2024 09 Apr 2024	Acceptable Acceptable
Sample Station	Sample Parameter: E. coli Sample Parameter: Total Coliform	<1 <1	09 Apr 2024 09 Apr 2024	Acceptable Acceptable
Pumphouse	Sample Parameter: E. coli Sample Parameter: Total Coliform	<1 <1	15 Apr 2024 15 Apr 2024	Acceptable Acceptable
Pumphouse	Sample Parameter: E. coli Sample Parameter: Total Coliform	<1 <1	08 May 2024 08 May 2024	Acceptable Acceptable
Sample Station	Sample Parameter: E. coli Sample Parameter: Total Coliform	<1 <1	08 May 2024 08 May 2024	Acceptable Acceptable
Pumphouse	Sample Parameter: E. coli Sample Parameter: Total Coliform	<1 <1	14 May 2024 14 May 2024	Acceptable Acceptable
Sample Station	Sample Parameter: E. coli Sample Parameter: Total Coliform	<1 <1	14 May 2024 14 May 2024	Acceptable Acceptable
Upper Pumphouse	Sample Parameter: E. coli Sample Parameter: Total Coliform	<1 <1	15 May 2024 15 May 2024	Acceptable Acceptable
Lower Pumphouse	Sample Parameter: E. coli Sample Parameter: Total Coliform	<1 <1	15 May 2024 15 May 2024	Acceptable Acceptable
Sample Station	Sample Parameter: E. coli Sample Parameter: Total Coliform	<1 <1	15 May 2024 15 May 2024	Acceptable Acceptable
Pumphouse	Sample Parameter: E. coli Sample Parameter: Total Coliform	<1 <1	03 Jun 2024 03 Jun 2024	Acceptable Acceptable
Sample Station	Sample Parameter: E. coli Sample Parameter: Total Coliform	<1 <1	03 Jun 2024 03 Jun 2024	Acceptable Acceptable
Lower Well	Sample Parameter: E. coli Sample Parameter: Total Coliform	<1 <1	03 Jun 2024 03 Jun 2024	Acceptable Acceptable
Lower Well	Sample Parameter: E. coli Sample Parameter: Total Coliform	<1 <1	10 Jun 2024 10 Jun 2024	Acceptable Acceptable
Pumphouse	Sample Parameter: E. coli Sample Parameter: Total Coliform	<1 <1	10 Jun 2024 10 Jun 2024	Acceptable Acceptable
Sample Station	Sample Parameter: E. coli Sample Parameter: Total Coliform	<1 <1	10 Jun 2024 10 Jun 2024	Acceptable Acceptable
Lower Well	Sample Parameter: E. coli Sample Parameter: Total Coliform	<1 <1	08 Jul 2024 08 Jul 2024	Acceptable Acceptable
Sample Station	Sample Parameter: E. coli Sample Parameter: Total Coliform	<1 <1	08 Jul 2024 08 Jul 2024	Acceptable Acceptable
Pumphouse	Sample Parameter: E. coli Sample Parameter: Total Coliform	<1 <1	15 Jul 2024 15 Jul 2024	Acceptable Acceptable

2024 Russet Bluff Water System Annual Report

Facility and Sample Site: Russet Bluff Water System 2214 Grebe Drive, Williams Lake, BC	Test Type: Drinking Water – Bacteriological Unit of Measure: CFU per 100 ml	Value	Date Collected	Results
Lower Well	Sample Parameter: E. coli Sample Parameter: Total Coliform	<1 <1	15 Jul 2024 15 Jul 2024	Acceptable Acceptable
Sample Station	Sample Parameter: E. coli Sample Parameter: Total Coliform	<1 <1	15 Jul 2024 15 Jul 2024	Acceptable Acceptable
Sample Station	Sample Parameter: E. coli Sample Parameter: Total Coliform	<1 <1	12 Aug 2024 12 Aug 2024	Acceptable Acceptable
Lower Well	Sample Parameter: E. coli Sample Parameter: Total Coliform	<1 <1	12 Aug 2024 12 Aug 2024	Acceptable Acceptable
Upper Well	Sample Parameter: E. coli Sample Parameter: Total Coliform	<1 <1	12 Aug 2024 12 Aug 2024	Acceptable Acceptable
Pumphouse	Sample Parameter: E. coli Sample Parameter: Total Coliform	<1 <1	21 Aug 2024 21 Aug 2024	Acceptable Acceptable
Sample Station	Sample Parameter: E. coli Sample Parameter: Total Coliform	<1 <1	21 Aug 2024 21 Aug 2024	Acceptable Acceptable
Lower Well	Sample Parameter: E. coli Sample Parameter: Total Coliform	<1 <1	21 Aug 2024 21 Aug 2024	Acceptable Acceptable
Pumphouse	Sample Parameter: E. coli Sample Parameter: Total Coliform	<1 <1	10 Sep 2024 10 Sep 2024	Acceptable Acceptable
Sample Station	Sample Parameter: E. coli Sample Parameter: Total Coliform	<1 <1	10 Sep 2024 10 Sep 2024	Acceptable Acceptable
Lower Well	Sample Parameter: E. coli Sample Parameter: Total Coliform	<1 <1	10 Sep 2024 10 Sep 2024	Acceptable Acceptable
Pumphouse	Sample Parameter: E. coli Sample Parameter: Total Coliform	<1 <1	17 Sep 2024 17 Sep 2024	Acceptable Acceptable
Sample Station	Sample Parameter: E. coli Sample Parameter: Total Coliform	<1 <1	17 Sep 2024 17 Sep 2024	Acceptable Acceptable
Lower Well	Sample Parameter: E. coli Sample Parameter: Total Coliform	<1 <1	17 Sep 2024 17 Sep 2024	Acceptable Acceptable
Pumphouse	Sample Parameter: E. coli Sample Parameter: Total Coliform	<1 <1	02 Oct 2024 02 Oct 2024	Acceptable Acceptable
Sample Station	Sample Parameter: E. coli Sample Parameter: Total Coliform	<1 <1	02 Oct 2024 02 Oct 2024	Acceptable Acceptable
Pumphouse	Sample Parameter: E. coli Sample Parameter: Total Coliform	<1 <1	15 Oct 2024 15 Oct 2024	Acceptable Acceptable
Sample Station	Sample Parameter: E. coli Sample Parameter: Total Coliform	<1 <1	15 Oct 2024 15 Oct 2024	Acceptable Acceptable
Pumphouse	Sample Parameter: E. coli Sample Parameter: Total Coliform	<1 <1	04 Nov 2024 04 Nov 2024	Acceptable Acceptable
Sample Station	Sample Parameter: E. coli Sample Parameter: Total Coliform	<1 <1	04 Nov 2024 04 Nov 2024	Acceptable Acceptable
Pumphouse	Sample Parameter: E. coli Sample Parameter: Total Coliform	<1 <1	12 Nov 2024 12 Nov 2024	Acceptable Acceptable
Sample Station	Sample Parameter: E. coli Sample Parameter: Total Coliform	<1 <1	12 Nov 2024 12 Nov 2024	Acceptable Acceptable
Pumphouse	Sample Parameter: E. coli Sample Parameter: Total Coliform	<1 <1	02 Dec 2024 02 Dec 2024	Acceptable Acceptable
Sample Station	Sample Parameter: E. coli Sample Parameter: Total Coliform	<1 <1	02 Dec 2024 02 Dec 2024	Acceptable Acceptable
Pumphouse	Sample Parameter: E. coli Sample Parameter: Total Coliform	<1 <1	09 Dec 2024 09 Dec 2024	Acceptable Acceptable
Sample Station	Sample Parameter: E. coli Sample Parameter: Total Coliform	<1 <1	09 Dec 2024 09 Dec 2024	Acceptable Acceptable

2024 Russet Bluff Water System Annual Report

Page : 4 of 7
 Work Order : KS2400865
 Client : Cariboo Regional District
 Project : Drinking Water



Analytical Results Evaluation

Matrix: Water				Client sample ID	Alexis Creek	Lexington	Russet Bluff	---	---	---	---
				Sampling date/time	12-Mar-2024 02:30	12-Mar-2024 02:30	12-Mar-2024 02:30	---	---	---	---
				Sub-Matrix	Water	Water	Water	---	---	---	---
Analyte	CAS Number	Method/Lab	Unit	KS2400865-001	KS2400865-002	KS2400865-003	-----	-----	-----	-----	-----
Physical Tests											
Alkalinity, total (as CaCO ₃)	---	E290/VA	mg/L	277	366	604	---	---	---	---	---
Colour, true	---	E329/VA	CU	<5.0	<5.0	<5.0	---	---	---	---	---
Conductivity	---	E100/VA	µS/cm	581	1410	1200	---	---	---	---	---
pH	---	E108/VA	pH units	8.39	8.37	8.45	---	---	---	---	---
Solids, total dissolved [TDS]	---	E162/VA	mg/L	347	906	604	---	---	---	---	---
Turbidity	---	E121/VA	NTU	<0.10	0.65	<0.10	---	---	---	---	---
Hardness (as CaCO ₃), from total Ca/Mg	---	EC100A/VA	mg/L	191	528	708	---	---	---	---	---
Anions and Nutrients											
Chloride	16887-00-6	E235.CI/VA	mg/L	5.74	57.3	39.7	---	---	---	---	---
Fluoride	16984-48-8	E235.F/VA	mg/L	0.157	0.112	<0.100 ^{DLDS}	---	---	---	---	---
Nitrate (as N)	14797-55-8	E235.NO3-L/VA	mg/L	0.382	<0.0250 ^{DLDS}	0.990	---	---	---	---	---
Nitrite (as N)	14797-65-0	E235.NO2-L/VA	mg/L	<0.0010	<0.0050 ^{DLDS}	<0.0050 ^{DLDS}	---	---	---	---	---
Sulfate (as SO ₄)	14808-79-8	E235.SO4/VA	mg/L	31.9	339	63.0	---	---	---	---	---
Total Metals											
Aluminum, total	7429-90-5	E420/VA	mg/L	---	<0.0030	---	---	---	---	---	---
Aluminum, total	7429-90-5	E420/VA	mg/L	<0.0100	---	<0.0100	---	---	---	---	---
Antimony, total	7440-36-0	E420/VA	mg/L	---	<0.00010	---	---	---	---	---	---
Antimony, total	7440-36-0	E420/VA	mg/L	<0.00050	---	<0.00050	---	---	---	---	---
Arsenic, total	7440-38-2	E420/VA	mg/L	0.00310	0.00887	0.00253	---	---	---	---	---
Barium, total	7440-39-3	E420/VA	mg/L	---	0.00891	---	---	---	---	---	---
Barium, total	7440-39-3	E420/VA	mg/L	<0.0200	---	0.0225	---	---	---	---	---
Boron, total	7440-42-8	E420/VA	mg/L	---	0.123	---	---	---	---	---	---
Boron, total	7440-42-8	E420/VA	mg/L	<0.100	---	0.212	---	---	---	---	---
Cadmium, total	7440-43-9	E420/VA	mg/L	---	<0.0000150 ^{DLM}	---	---	---	---	---	---
Cadmium, total	7440-43-9	E420/VA	mg/L	<0.000200	---	<0.000200	---	---	---	---	---
Calcium, total	7440-70-2	E420/VA	mg/L	---	50.0	---	---	---	---	---	---
Calcium, total	7440-70-2	E420/VA	mg/L	20.6	---	10.0	---	---	---	---	---

2024 Russet Bluff Water System Annual Report

Page : 5 of 7
 Work Order : KS2400865
 Client : Cariboo Regional District
 Project : Drinking Water



Analytical Results Evaluation

Matrix: Water				Client sample ID	Alexis Creek	Lexington	Russet Bluff	----	----	----	----
				Sampling date/time	12-Mar-2024 02:30	12-Mar-2024 02:30	12-Mar-2024 02:30	----	----	----	----
				Sub-Matrix	Water	Water	Water	----	----	----	----
Analyte	CAS Number	Method/Lab	Unit	KS2400865-001	KS2400865-002	KS2400865-003	-----	-----	-----	-----	-----
Total Metals											
Chromium, total	7440-47-3	E420/VA	mg/L	----	<0.00050	----	----	----	----	----	----
Chromium, total	7440-47-3	E420/VA	mg/L	0.00829	----	0.0116	----	----	----	----	----
Copper, total	7440-50-8	E420/VA	mg/L	----	0.00051	----	----	----	----	----	----
Copper, total	7440-50-8	E420/VA	mg/L	0.00148	----	0.00433	----	----	----	----	----
Iron, total	7439-89-6	E420/VA	mg/L	----	0.167	----	----	----	----	----	----
Iron, total	7439-89-6	E420/VA	mg/L	<0.030	----	<0.030	----	----	----	----	----
Lead, total	7439-92-1	E420/VA	mg/L	----	<0.000050	----	----	----	----	----	----
Lead, total	7439-92-1	E420/VA	mg/L	<0.000500	----	<0.000500	----	----	----	----	----
Magnesium, total	7439-95-4	E420/VA	mg/L	----	98.0	----	----	----	----	----	----
Magnesium, total	7439-95-4	E420/VA	mg/L	33.9	----	166	----	----	----	----	----
Manganese, total	7439-96-5	E420/VA	mg/L	----	0.102	----	----	----	----	----	----
Manganese, total	7439-96-5	E420/VA	mg/L	<0.00200	----	<0.00200	----	----	----	----	----
Mercury, total	7439-97-6	E508/VA	mg/L	<0.0000050	<0.0000050	<0.0000050	----	----	----	----	----
Potassium, total	7440-09-7	E420/VA	mg/L	----	6.06	----	----	----	----	----	----
Potassium, total	7440-09-7	E420/VA	mg/L	6.03	----	7.38	----	----	----	----	----
Selenium, total	7782-49-2	E420/VA	mg/L	----	<0.000050	----	----	----	----	----	----
Selenium, total	7782-49-2	E420/VA	mg/L	0.00537	----	0.00247	----	----	----	----	----
Sodium, total	7440-23-5	E420/VA	mg/L	----	110	----	----	----	----	----	----
Sodium, total	7440-23-5	E420/VA	mg/L	62.6	----	32.3	----	----	----	----	----
Uranium, total	7440-61-1	E420/VA	mg/L	----	0.000987	----	----	----	----	----	----
Uranium, total	7440-61-1	E420/VA	mg/L	0.00574	----	<0.000100	----	----	----	----	----
Zinc, total	7440-66-6	E420/VA	mg/L	----	<0.0030	----	----	----	----	----	----
Zinc, total	7440-66-6	E420/VA	mg/L	<0.0500	----	<0.0500	----	----	----	----	----

Please refer to the General Comments section for an explanation of any result qualifiers detected.

Please refer to the Accreditation section for an explanation of analyte accreditations.

Page : 6 of 7
 Work Order : KS2400865
 Client : Cariboo Regional District
 Project : Drinking Water



Summary of Guideline Limits

Analyte	CAS Number	Unit	BCDWQG AO	BCDWQG MAC	BCDWQG OG				
Physical Tests									
Alkalinity, total (as CaCO ₃)	----	mg/L	--	--	--				
Colour, true	----	CU	15 CU	--	--				
Conductivity	----	µS/cm	--	--	--				
Hardness (as CaCO ₃), from total Ca/Mg	----	mg/L	--	--	--				
pH	----	pH units	--	--	7 - 10.5 pH units				
Solids, total dissolved [TDS]	----	mg/L	500 mg/L	--	--				
Turbidity	----	NTU	--	1 NTU	--				
Anions and Nutrients									
Chloride	16887-00-6	mg/L	250 mg/L	--	--				
Fluoride	16984-48-8	mg/L	--	1.5 mg/L	--				
Nitrate (as N)	14797-55-8	mg/L	--	10 mg/L	--				
Nitrite (as N)	14797-65-0	mg/L	--	1 mg/L	--				
Sulfate (as SO ₄)	14808-79-8	mg/L	500 mg/L	--	--				
Total Metals									
Aluminum, total	7429-90-5	mg/L	--	2.9 mg/L	--				
Antimony, total	7440-36-0	mg/L	--	0.006 mg/L	--				
Arsenic, total	7440-38-2	mg/L	--	0.01 mg/L	--				
Barium, total	7440-39-3	mg/L	--	2 mg/L	--				
Boron, total	7440-42-8	mg/L	--	5 mg/L	--				
Cadmium, total	7440-43-9	mg/L	--	0.007 mg/L	--				
Calcium, total	7440-70-2	mg/L	--	--	--				
Chromium, total	7440-47-3	mg/L	--	0.05 mg/L	--				
Copper, total	7440-50-8	mg/L	1 mg/L	2 mg/L	--				
Iron, total	7439-89-6	mg/L	0.3 mg/L	--	--				
Lead, total	7439-92-1	mg/L	--	0.005 mg/L	--				
Magnesium, total	7439-95-4	mg/L	--	--	--				
Manganese, total	7439-96-5	mg/L	0.02 mg/L	0.12 mg/L	--				
Mercury, total	7439-97-6	mg/L	--	0.001 mg/L	--				
Potassium, total	7440-09-7	mg/L	--	--	--				
Selenium, total	7782-49-2	mg/L	--	0.05 mg/L	--				
Sodium, total	7440-23-5	mg/L	200 mg/L	--	--				
Uranium, total	7440-61-1	mg/L	--	0.02 mg/L	--				
Zinc, total	7440-66-6	mg/L	5 mg/L	--	--				

Please refer to the General Comments section for an explanation of any qualifiers detected.

Page : 7 of 7
Work Order : KS2400865
Client : Cariboo Regional District
Project : Drinking Water



Key:

BCDWQG	British Columbia Drinking Water Quality Guidelines (JAN, 2023)
AO	Aesthetic Objective/Other Value
MAC	Maximum Acceptable Concentrations
OG	Operational Guidance

Page : 3 of 3
 Work Order : KS2401919
 Client : Cariboo Regional District
 Project : Drinking Water



Analytical Results Evaluation

				Client sample ID						
Matrix: Water				Lexington (Pump House)	Russet Bluff Lower Well	---	---	---	---	---
				Sampling date/time						
				27-May-2024 10:55	27-May-2024 11:20	---	---	---	---	---
				Sub-Matrix						
				Water	Water	---	---	---	---	---
Analyte	CAS Number	Method/Lab	Unit	KS2401919-001	KS2401919-002	-----	-----	-----	-----	-----
Total Metals										
Arsenic, total	7440-38-2	E420/VA	mg/L	0.00942	---	---	---	---	---	---
Manganese, total	7439-96-5	E420/VA	mg/L	---	0.304	---	---	---	---	---

Please refer to the General Comments section for an explanation of any result qualifiers detected.

Please refer to the Accreditation section for an explanation of analyte accreditations.

Key:

Page : 3 of 3
 Work Order : KS2402196
 Client : Cariboo Regional District
 Project : ---



Analytical Results Evaluation

				Client sample ID	Lexington (Pump House)	Russet Bluff (Lower Well)	----	----	----	----	----
Matrix: Water				Sampling date/time	11-Jun-2024 09:18	11-Jun-2024 13:20	----	----	----	----	----
				Sub-Matrix	Water	Water	----	----	----	----	----
Analyte	CAS Number	Method/Lab	Unit	KS2402196-001	KS2402196-002	-----	-----	-----	-----	-----	-----
Anions and Nutrients											
Nitrate (as N)	14797-55-8	E235.NO3-LVA	mg/L	<0.0250 ^{DLDS}	----	----	----	----	----	----	----
Total Metals											
Arsenic, total	7440-38-2	E420/VA	mg/L	0.00951	----	----	----	----	----	----	----
Manganese, total	7439-96-5	E420/VA	mg/L	----	0.294	----	----	----	----	----	----

Please refer to the General Comments section for an explanation of any result qualifiers detected.
 Please refer to the Accreditation section for an explanation of analyte accreditations.

Summary of Guideline Limits

Analyte	CAS Number	Unit	BCDWQG AO	BCDWQG MAC					
Anions and Nutrients									
Nitrate (as N)	14797-55-8	mg/L		10 mg/L					
Total Metals									
Arsenic, total	7440-38-2	mg/L		0.01 mg/L					
Manganese, total	7439-96-5	mg/L	0.02 mg/L	0.12 mg/L					

Please refer to the General Comments section for an explanation of any qualifiers detected.

Key:
 BCDWQG British Columbia Drinking Water Quality Guidelines (JAN, 2023)
 AO Aesthetic Objective/Other Value
 MAC Maximum Acceptable Concentrations

2024 Russet Bluff Water System Annual Report



Page : 4 of 8
 Work Order : KS2402662
 Client : Cariboo Regional District
 Project : Drinking Water - Full Chemical Russet Bluff Lower Well

Analytical Results

Sub-Matrix: Water (Matrix: Water)		Client sample ID Sampling date/time		Russet Bluff Lower Well						
				09-Jul-2024 09:50						
Analyte	Method/Lab	LOR	Unit	KS2402662-002	BCDWQG AO	BCDWQG MAC	BCDWQG OG	--	--	--
Physical Tests										
Absorbance, UV (@ 254nm), unfiltered	E405/VA	0.0050	AU/cm	0.0970	--	--	--	--	--	--
Alkalinity, bicarbonate (as CaCO3)	E290/VA	1.0	mg/L	782	--	--	--	--	--	--
Alkalinity, carbonate (as CaCO3)	E290/VA	1.0	mg/L	10.6	--	--	--	--	--	--
Alkalinity, hydroxide (as CaCO3)	E290/VA	1.0	mg/L	<1.0	--	--	--	--	--	--
Alkalinity, phenolphthalein (as CaCO3)	E290/VA	1.0	mg/L	5.3	--	--	--	--	--	--
Alkalinity, total (as CaCO3)	E290/VA	1.0	mg/L	793	--	--	--	--	--	--
Colour, true	E329/VA	5.0	CU	<5.0	15 CU	--	--	--	--	--
Conductivity	E100/VA	2.0	µS/cm	2180	--	--	--	--	--	--
Hardness (as CaCO3), from total Ca/Mg	EC100A/VA	0.60	mg/L	1170	--	--	--	--	--	--
Langelier index (@ 15°C)	EC105A/VA	0.010	-	1.29	--	--	--	--	--	--
Langelier index (@ 20°C)	EC105A/VA	0.010	-	1.36	--	--	--	--	--	--
Langelier index (@ 25°C)	EC105A/VA	0.010	-	1.43	--	--	--	--	--	--
Langelier index (@ 4°C)	EC105A/VA	0.010	-	1.12	--	--	--	--	--	--
Langelier index (@ 60°C)	EC105A/VA	0.010	-	1.86	--	--	--	--	--	--
Langelier index (@ 77°C)	EC105A/VA	0.010	-	2.05	--	--	--	--	--	--
pH	E108/VA	0.10	pH units	8.28	--	--	7 - 10.5 pH units	--	--	--
Solids, total dissolved [TDS]	E162/VA	10	mg/L	1620	500 mg/L	--	--	--	--	--
Turbidity	E121/VA	0.10	NTU	0.18	--	1 NTU	--	--	--	--
Transmittance, UV (@ 254nm), unfiltered	E405/VA	1.0	% T/cm	80.0	--	--	--	--	--	--
Anions and Nutrients										
Ammonia, total (as N)	E298/VA	0.0050	mg/L	0.114	--	--	--	--	--	--
Bromide	E235.Br-L/VA	0.050	mg/L	<0.500	DLDS	--	--	--	--	--
Chloride	E235.Cl/VA	0.50	mg/L	247	250 mg/L	--	--	--	--	--
Fluoride	E235.F/VA	0.020	mg/L	<0.200	DLDS	--	1.5 mg/L	--	--	--
Kjeldahl nitrogen, total [TKN]	E318/VA	0.050	mg/L	0.461	--	--	--	--	--	--

2024 Russet Bluff Water System Annual Report



Page : 5 of 8
 Work Order : KS2402662
 Client : Cariboo Regional District
 Project : Drinking Water - Full Chemical Russet Bluff Lower Well

Analyte	Method/Lab	LOR	Unit	KS2402662-002 (Continued)	BCDWQG AO	BCDWQG MAC	BCDWQG OG	--	--	--
Anions and Nutrients - Continued										
Nitrate (as N)	E235.NO3-L/VA	0.0050	mg/L	0.834	--	10 mg/L	--	--	--	--
Nitrite (as N)	E235.NO2-L/VA	0.0010	mg/L	0.0722	--	1 mg/L	--	--	--	--
Nitrogen, total organic	EC363/VA	0.050	mg/L	0.347	--	--	--	--	--	--
Sulfate (as SO4)	E235.SO4/VA	0.30	mg/L	138	500 mg/L	--	--	--	--	--
Cyanides										
Cyanide, strong acid dissociable (Total)	E333/VA	0.0050	mg/L	<0.0050	--	--	--	--	--	--
Organic / Inorganic Carbon										
Carbon, total organic [TOC]	E355-L/VA	0.50	mg/L	5.12	--	--	--	--	--	--
Microbiological Tests										
Coliforms, total	E010/KS	1	MPN/100mL	<1	--	1 MPN/100mL	--	--	--	--
Coliforms, Escherichia coli [E. coli]	E010/KS	1	MPN/100mL	<1	--	1 MPN/100mL	--	--	--	--
Ion Balance										
Anion sum	EC101A/VA	0.10	meq/L	25.8	--	--	--	--	--	--
Cation sum (total)	EC101A/VA	0.10	meq/L	26.1	--	--	--	--	--	--
Ion balance (APHA)	EC101A/VA	0.010	%	0.578	--	--	--	--	--	--
Total Metals										
Aluminum, total	E420/VA	0.0030	mg/L	<0.0030	--	2.9 mg/L	--	--	--	--
Antimony, total	E420/VA	0.00010	mg/L	0.00014	--	0.006 mg/L	--	--	--	--
Arsenic, total	E420/VA	0.00010	mg/L	0.00438	--	0.01 mg/L	--	--	--	--
Barium, total	E420/VA	0.00010	mg/L	0.0109	--	2 mg/L	--	--	--	--
Beryllium, total	E420/VA	0.000100	mg/L	<0.000100	--	--	--	--	--	--
Bismuth, total	E420/VA	0.000050	mg/L	<0.000050	--	--	--	--	--	--
Boron, total	E420/VA	0.010	mg/L	0.266	--	5 mg/L	--	--	--	--
Cadmium, total	E420/VA	0.0000050	mg/L	<0.0000050	--	0.007 mg/L	--	--	--	--
Calcium, total	E420/VA	0.050	mg/L	65.0	--	--	--	--	--	--
Cesium, total	E420/VA	0.000010	mg/L	<0.000010	--	--	--	--	--	--
Chromium, total	E420/VA	0.00050	mg/L	<0.00050	--	0.05 mg/L	--	--	--	--
Cobalt, total	E420/VA	0.00010	mg/L	0.00026	--	0.001 mg/L	--	--	--	--
Copper, total	E420/VA	0.00050	mg/L	0.00122	1 mg/L	2 mg/L	--	--	--	--
Iron, total	E420/VA	0.010	mg/L	0.038	0.3 mg/L	--	--	--	--	--
Lead, total	E420/VA	0.000050	mg/L	<0.000050	--	0.005 mg/L	--	--	--	--
Lithium, total	E420/VA	0.0010	mg/L	0.0024	--	--	--	--	--	--
Magnesium, total	E420/VA	0.0050	mg/L	244	--	--	--	--	--	--
Manganese, total	E420/VA	0.00010	mg/L	0.284	0.02 mg/L	0.12 mg/L	--	--	--	--

2024 Russet Bluff Water System Annual Report



Page : 6 of 8
 Work Order : KS2402662
 Client : Cariboo Regional District
 Project : Drinking Water - Full Chemical Russet Bluff Lower Well

Analyte	Method/Lab	LOR	Unit	KS2402662-002 (Continued)	BCDWQG AO	BCDWQG MAC	BCDWQG OG	--	--	--
Total Metals - Continued										
Mercury, total	E508/VA	0.000050	mg/L	<0.000050	--	0.001 mg/L	--	--	--	--
Molybdenum, total	E420/VA	0.000050	mg/L	0.00938	--	--	--	--	--	--
Nickel, total	E420/VA	0.00050	mg/L	0.00547	--	--	--	--	--	--
Phosphorus, total	E420/VA	0.050	mg/L	0.195	0.01 mg/L	--	--	--	--	--
Potassium, total	E420/VA	0.050	mg/L	8.35	--	--	--	--	--	--
Rubidium, total	E420/VA	0.00020	mg/L	0.00280	--	--	--	--	--	--
Selenium, total	E420/VA	0.000050	mg/L	0.00105	--	0.05 mg/L	--	--	--	--
Silicon, total	E420/VA	0.10	mg/L	12.3	--	--	--	--	--	--
Silver, total	E420/VA	0.000010	mg/L	<0.000010	--	--	--	--	--	--
Sodium, total	E420/VA	0.050	mg/L	59.1	200 mg/L	--	--	--	--	--
Strontium, total	E420/VA	0.00020	mg/L	0.277	--	7 mg/L	--	--	--	--
Sulfur, total	E420/VA	0.50	mg/L	52.0	--	--	--	--	--	--
Tellurium, total	E420/VA	0.00020	mg/L	<0.00020	--	--	--	--	--	--
Thallium, total	E420/VA	0.000010	mg/L	<0.000010	--	--	--	--	--	--
Thorium, total	E420/VA	0.00010	mg/L	<0.00010	--	--	--	--	--	--
Tin, total	E420/VA	0.00010	mg/L	<0.00010	--	--	--	--	--	--
Titanium, total	E420/VA	0.00030	mg/L	<0.00030	--	--	--	--	--	--
Tungsten, total	E420/VA	0.00010	mg/L	<0.00010	--	--	--	--	--	--
Uranium, total	E420/VA	0.000010	mg/L	0.00381	--	0.02 mg/L	--	--	--	--
Vanadium, total	E420/VA	0.00050	mg/L	0.00158	--	--	--	--	--	--
Zinc, total	E420/VA	0.0030	mg/L	<0.0030	5 mg/L	--	--	--	--	--
Zirconium, total	E420/VA	0.00020	mg/L	<0.00100	DLM	--	--	--	--	--

Please refer to the General Comments section for an explanation of any result qualifiers detected.

Please refer to the Accreditation section for an explanation of analyte accreditations.

Summary of Guideline Breaches by Sample

SampleID/Client ID	Matrix	Analyte	Analyte Summary	Guideline	Category	Result	Limit
Russet Bluff Lower Well	Water	Solids, total dissolved [TDS]		BCDWQG	AO	1620 mg/L	500 mg/L
	Water	Manganese, total		BCDWQG	AO	0.284 mg/L	0.02 mg/L
	Water	Phosphorus, total		BCDWQG	AO	0.195 mg/L	0.01 mg/L
	Water	Manganese, total		BCDWQG	MAC	0.284 mg/L	0.12 mg/L



Page : 7 of 8
Work Order : KS2402662
Client : Cariboo Regional District
Project : Drinking Water - Full Chemical Russet Bluff Lower Well

Key:

BCDWQG	British Columbia Drinking Water Quality Guidelines (JAN, 2023)
AO	Aesthetic Objective/Other Value
MAC	Maximum Acceptable Concentrations
OG	Operational Guidance



Page : 8 of 8
 Work Order : KS2402662
 Client : Cariboo Regional District
 Project : Drinking Water - Full Chemical Russet Bluff Lower Well

Analytical Results

			Client sample ID	Russet Bluff Lower Well						
Sub-Matrix: Water (Matrix: Water)			Sampling date/time	09-Jul-2024 09:53						
Analyte	Method/Lab	LOR	Unit	KS2402662-003	BCDWQG MAC	--	--	--	--	--
Total Metals										
Arsenic, total	E420/VA	0.00010	mg/L	0.00438	0.01 mg/L	--	--	--	--	--

Please refer to the General Comments section for an explanation of any result qualifiers detected.
 Please refer to the Accreditation section for an explanation of analyte accreditations.

No Breaches Found

Key:
 BCDWQG British Columbia Drinking Water Quality Guidelines (JAN, 2023)
 MAC Maximum Acceptable Concentrations

Appendix C: Emergency Plans

2025 Cariboo Regional District

Emergency Response & Contingency Plan

Russet Bluff Water System

*Utilities, Communications, and Emergency Operations Departments
1-1-2025*

By Kelly McDonald, Cheryl McMullen, Gerald Pinchbeck, Ken Heidema and Charles Howes

Contents

SECTION 1: Emergency Plan Goals.....	4
1.1. Resiliency in Operations.....	4
1.1.1. Emergency Response Plan	4
1.1.2. Regional Agency Coordination	4
1.1.3. Mutual Aid Agreements	4
1.1.4. Emergency Power	5
1.1.5. Ability to Meet Water Demands	5
1.1.6. Critical Parts Inventory	5
1.1.7. Critical Staff Resiliency	5
SECTION 2: How to Use This Plan	5
SECTION 3: Emergency Planning Definitions	5
SECTION 4: Emergency Scenarios	6
4.1. Introduction	6
4.2. Emergency Scenario Format	6
4.2.1. Description of Emergency	6
4.2.2. Indicators.....	6
4.2.3. Actions.....	6
4.2.4. Contacts	6
4.2.5. Event Record	6
SECTION 5: Water Supply Contamination	7
5.1. Potential Causes.....	7
5.1.1. Chemical Spill	7
5.1.2. Flood Event.....	7
5.1.3. Confirmed Cross Connection	7
5.1.4. System Breach.....	7
5.1.5. Positive Sample Result	7
5.1.6. Vandalism.....	7
SECTION 6: Supply Disruption	8

Russet Bluff Water System – 2025 Emergency Response and Contingency Plan

6.1. Equipment Failure	8
6.2. Supply Main Break	9
6.3. Extended Loss of BC Hydro Power Supply	10
6.4. Operator Transportation Routes Compromised	11
6.4.1. Potential Causes	11
SECTION 7: Cyber Incident	12
7.1. Introduction	12
7.2. IT and/or IT Contractor Steps	13
SECTION 8: Drought	14
8.1 Introduction	14
Appendix A: Contacts	15
Cariboo Regional District Administrative Staff Emergency Contact Numbers	16
Cariboo Regional District Water Operators	16
Provincial and Federal Contacts	16
Contractors	17
Municipalities	17
Media (Communications Department Leads)	17
Appendix B: Charts	18
Water Main Break	19
Critical Parts Inventory	19
Appendix C: Drought Management Plan	21
Priority Users	22
Water Restrictions and Conservation Measures	22
Communication Plan	22
Supplemental or Alternate Sources of Potable Water	24
Operational Procedures	25
Appendix D: Templates	26
Damage Assessment Summary (EOC 415)	27
Action Plan (EOC 502)	28

Russet Bluff Water System – 2025 Emergency Response and Contingency Plan

Situation Report (EOC 501) 29

Event Log (EOC 414) 30

Appendix E: Communications Templates..... 31

SECTION 1: Emergency Plan Goals

The Objective of the Cariboo Regional District (CRD) Emergency Response and Contingency Plan (ERCP) is to provide staff and regulatory agencies with a guideline for potential water utility related emergencies.

This Emergency Response and Contingency Plan (ERCP) serves as a guideline to address various emergency situations, recognizing that no two emergencies are exactly alike. Each emergency is described with a general sequence of steps to follow, providing both a structured approach to response and a consistent method for documenting actions taken. Task lists within each emergency section also function as checklists to remind staff of critical items to consider and complete during an emergency. This ERCP includes specific protocols and considerations for the CRD water supply system.

This plan has been prepared to guide the Cariboo Regional District to respond to an emergency arising in the operation of the Russet Bluff Water System. The purpose of the ERCP is to:

- ✓ Ensure staff and the public's safety in carrying out emergency tasks.
- ✓ Provide the earliest and safest response to an emergency condition.
- ✓ Ensure that water quality and public health are not compromised.
- ✓ Ensure that water for firefighting is available.
- ✓ Restore normal water system operation.
- ✓ Protect the natural environment from impacts associated with the system operation in the event of an emergency.
- ✓ Contain property damage.

1.1. Resiliency in Operations

Operational resiliency refers to the capability of an operation to adjust, adapt, and maintain service delivery under emergency conditions. The objective for the CRD Water Utility is to achieve high operational resiliency. Indicators of operational resiliency include the following:

- 1.1.1. **Emergency Response Plan:** A comprehensive ERP is essential in building resilience within operations, providing structured guidance for handling emergencies effectively. This document is an integral part of that resiliency framework.
- 1.1.2. **Regional Agency Coordination:** The ERCP must be shared with regional emergency response agencies, ensuring cohesive support. The CRD Emergency Operations Department serves as the local staging agency for the Provincial Emergency Program.
- 1.1.3. **Mutual Aid Agreements:** In certain emergencies, the CRD may need support from neighboring water utilities. Williams Lake is a nearby utility from which the CRD may

seek assistance in the future. The CRD is working toward a formal mutual aid agreement based on community protection principles.

- 1.1.4. **Emergency Power:** The Russet Bluff Water System can operate on gravity-fed supply. A standard battery pack is on hand to maintain disinfection if the power grid fails.
- 1.1.5. **Ability to Meet Water Demands:** While the water system meets current demands, the reservoir is small, and there are no fire hydrants in the service area.
- 1.1.6. **Critical Parts Inventory:** Appendix B provides a list of critical parts and their availability. Appendix A includes contact names for Cariboo support agencies offering specialized parts or services.
- 1.1.7. **Critical Staff Resiliency:** Staff's ability to respond and remain calm during extreme events is only evident when tested. Training and reinforcement of sound decision-making at all levels will support preparedness for emergency situations.

SECTION 2: How to Use This Plan

The Water System Emergency Response and Contingency Plan (ERCP) is a guide for handling water system emergencies. The “Actions” section outlines various potential emergencies and provides steps to help minimize further damage.

After an emergency, the CRD will complete a Post Incident Report (see Appendix D). Regular review exercises and updates will strengthen our emergency response capabilities. We ask all plan holders to participate and offer recommendations to continually improve the ERCP.

Remember, the ERCP is only effective if everyone reviews, understands, and contributes to its ongoing development.

SECTION 3: Emergency Planning Definitions

This section provides emergency planning definitions used in this document, following *AWWA Manual 19: Emergency Planning for Water Utilities*.

Emergency: An unexpected event that may compromise water quality or reduce the availability of domestic, irrigation, or fire flow water for the community.

Minor Emergency: A localized, routine incident impacting a small number of customers, such as a small pipe break, vehicle collision with a hydrant, brief power outage, or minor service repair. Minor emergencies should be manageable without special resources and, if effectively handled, can be prevented from escalating into major emergencies.

Major Emergency: A significant event affecting a large portion of the water system, posing risks to water quality or quantity and potentially endangering community health and safety. Major emergencies are rare but impactful.

Natural Disaster: Events caused by natural forces beyond human control, including wildfires, earthquakes, floods, tornadoes, heat domes, freezing, and other severe weather-related incidents.

Human-Caused Disaster: Disasters resulting from human actions, whether accidental or intentional. These may include human error, accidents, labor disputes, negligence, vandalism, sabotage, terrorism, biological contamination, or chemical spills.

Hazard: A source of potential harm or danger linked to a disaster, such as unstable slopes from a creek wash-out or ground shaking from an earthquake.

Lifeline Supply: Essential community services that support health, safety, and sustenance. Lifeline utilities include water, wastewater, electricity, and natural gas, as well as critical transportation, communication, healthcare, and emergency operations centres.

SECTION 4: Emergency Scenarios

4.1. Introduction

Sections 5 and 6 list potential water system emergencies related to the physical components of the water supply. Section 7 describes the steps for a cyber threat or vandalism.

4.2. Emergency Scenario Format

Each emergency scenario in this ERCP follows a consistent format:

- 4.2.1. **Description of Emergency:** Describes each potential emergency for easy reference. Sections 5 and 6 cover physical water service issues, while Section 7 addresses cyber incidents and vandalism.
- 4.2.2. **Indicators:** Outlines how each emergency can be recognized, either by CRD staff or external contacts.
- 4.2.3. **Actions:** Lists response steps for CRD staff, generally in recommended order. This list serves as a guideline, and the lead Water Operator can use the provided checklist to verify all necessary actions are taken.
- 4.2.4. **Contacts:** Lists relevant contact agencies; specific contacts are found in the ERCP's Communications Section.
- 4.2.5. **Event Record:** A checklist at the page bottom summarizes the event, records whether photos were taken, and tracks emergency reporting.

All events, including minor repairs and leaks, should be documented and sent to the CRD Office for electronic filing. Each event should be recorded by date. Large events should have dedicated folders containing photos and data, following a standardized naming protocol.

SECTION 5: Water Supply Contamination

Description of Emergency: Contamination has been detected or possible contamination is present.

Indicators: Public notification (taste, odour or colour observations), poor water sample results, visible observations made by Water Operators, cross connection with potential contamination.

5.1. Potential Causes

- 5.1.1. Chemical Spill (e.g. transport truck, industry)
- 5.1.2. Flood Event
- 5.1.3. Confirmed Cross Connection
- 5.1.4. System Breach (e.g. water main break) *see 6.2.
- 5.1.5. Positive Sample Result (e.g. E. coli or other immediate threat to public health contaminant)
- 5.1.6. Vandalism

Actions:

- 1) Notify Water Operator.
- 2) Notify Drinking Water Officer (DWO).
- 3) Assess threat level (see Appendix B).
- 4) Notify Communications Department.
- 5) Water Operators to investigate site and inform Manager of Utilities of possible situation. Manager to contact Interior Health.
- 6) Confirm that the source of contaminant is mitigated.
- 7) If chemical contamination confirmed or highly suspected to be present:
 - a) Attempt to isolate.
 - b) Discuss with Engineer, Biologist/Chemist (Lab) and DWO to develop a reasonable and representative sampling program.
 - c) Contact Lab and arrange bottles if required and collect samples for rush analysis.

- 8) Report any spills to the Provincial Agency responsible (see Appendix A).
- 9) In an extreme situation of contamination, consider shutting down all supply pumps.
 - a) Pump station would shut off and “Do Not Use” notices would be provided to the public. CRD senior management would make this call.
- 10) Communication: Begin public notification if required and follow Water Quality Notification Procedures.
- 11) Continue discussion with appropriate experts for moving forward.
- 12) Discussions to consider alternate water source if needed. Involve Emergency Operations Department and Notify Fire Department.
- 13) Continue monitoring until water quality is back to normal and IH gives approval to lift advisory or notice.
- 14) Complete documentation:
 - a) Record of events, include times and dates.
 - b) Complete a comprehensive damage assessment.
 - c) Investigate potential causes.
 - d) After action report.

SECTION 6: Supply Disruption

6.1. Equipment Failure

Description of Emergency: This type of emergency is typically caused by extreme weather events that place a very high demand on the Water Treatment Plant, or any other situation where water demands are high, and equipment or infrastructure reduces the ability to maintain maximum output.

Indicators: Visual observations by Water Operators. Failure of equipment as identified by SCADA and alarms.

Actions:

- 1) Document Situation: Note date, time, location and means of event recognition.
- 2) Notify Water Operator.
- 3) Notify Manager.
- 4) Notify Communications Department.

Russet Bluff Water System – 2025 Emergency Response and Contingency Plan

- 5) If cause is identified as a main break, see section 6.2.
- 6) Well Site Investigation: Generally, this problem is caused by high flows and overheating VFD's.
- 7) Check in the pumphouse for mechanical issues such as temperatures on variable frequency drive (VFD) displays.
- 8) Check all SCADA pages and trends to determine what is operational, what has failed, or what is at risk of failure.
- 9) Check on alarms.
- 10) Note status of chlorine disinfection, reservoir level, source pump status, chemical dosing status, and raw water flows.
- 11) Check all necessary equipment to confirm proper functionality.
- 12) Check inventory for parts that may be available to aid in necessary repairs. If necessary, contact Williams Lake Public Works for assistance.
- 13) If the issue stems from the VFD's, allow to cool and contract electrician if necessary.
- 14) If issue is due to drawdown in Supply Well, consult Drought Management Plan (Appendix C) and proceed to next step.
- 15) If problem persists:
 - ✓ Communicate with Interior Health, issue an advisory as recommended (see Section 1).
 - ✓ Implement emergency water restrictions (Communications Department).
 - ✓ Contact Williams Lake Fire Department and CRD Protective Services Department to inform them of the situation.
- 16) Complete documentation:
 - a) Record of events, include times and dates.
 - b) Complete a comprehensive damage assessment.
 - c) Investigate potential causes.

6.2. Supply Main Break

Description of Emergency: Failure or damage to a water supply main causing loss of water and/or pressure.

Indicators: SCADA alarms indicating pressure loss, calls from residents or staff observations.

Actions: Steps to be taken by CRD staff:

- 1) Contact Manager of Utilities.
- 2) Contact Water Operator.
- 3) Determine location.
- 4) Stop the flow of water by closing valves and isolating the break, depending on the scale of the break (see chart in Appendix B); attempt to maintain positive pressure.
- 5) Contact Manager and describe the emergency.
- 6) Determine what section of the system has been affected by the depressurization.
- 7) If there is a potential that the system has been contaminated, the Manager of Utilities will contact Interior Health for recommendations on issuing a Water Advisory. See Appendix E (follow Communications procedures).
- 8) Make the site safe by implementing traffic control: block road, if necessary, contact traffic control contractor (see Appendix A).
- 9) If possible, mitigate danger to the public and further damage of infrastructure or property. If necessary and feasible, set up sediment control measures and de-chlorinated water released.
- 10) Assess immediate damage.
- 11) Coordinate repair plans with appropriate contractors (see contacts).
- 12) Contact the Provincial Agency responsible (see Appendix) for large discharges of chlorinated water including;
- 13) If there is significant sediment or chlorinated water in streams.
- 14) Call Fire Department to inform them when hydrants are in or out of service.
- 15) Complete documentation:
 - a) Record of events, include times and dates.
 - b) Complete a comprehensive damage assessment.
 - c) Investigate potential causes.
 - d) After action report.

6.3. Extended Loss of BC Hydro Power Supply

Description of Emergency: The loss of power will stop the pumping systems to supply water to the distribution system and from filling the reservoir. With no power, a full reservoir has approximately 48 hours of water available.

Indicators: SCADA alarms

Actions:

- 1) Source a generator.
- 2) Change system settings if necessary to keep reservoirs topped up.
- 3) If sudden phase loss or total power loss causes equipment failure see Section 6.
- 4) If issues with power supply persist:
 - ✓ Contact BC Hydro for information on the timelines for power restoration.
 - ✓ Communicate with Interior Health, issue an advisory as recommended (see Section 1).
 - ✓ Implement emergency water restrictions (Communications Department).
 - ✓ Potentially throttle down the pressure within the distribution to reduce water loss (always above 20 psi).
 - ✓ Contact Williams Lake Fire Department and CRD Protective Services Department to inform them of the situation.

6.4. Operator Transportation Routes Compromised

6.4.1. Potential Causes

- Forest fire
- Accident
- Mechanical issues with vehicle
- Construction

Description of Emergency: The usual transportation route to the Russet Bluff area is blocked (e.g., by a forest fire or accident), and no operator can be onsite to perform duties.

Actions:

- 1) Contact Manager of Utilities.
- 2) Manager will inform Interior Health Officer of situation.
- 3) Continue to monitor system using SCADA.
- 4) If issue persists:
 - ✓ Contact Williams Lake or other Regional Operators for assistance.

- ✓ Reach out to local contact if physical checks are needed. Preferably local contractor with system experience (see Appendix A).
- ✓ Contact the Communications Department to issue applicable advisories (at the recommendation of Interior Health).

5) Complete documentation:

- a) Record of events, include times and dates.
- b) Complete a comprehensive damage assessment.
- c) Investigate potential causes.

SECTION 7: Cyber Incident

7.1. Introduction

Cyberspace and its underlying infrastructure are vulnerable to a wide range of hazards from both physical attacks as well as cyberthreats. Sophisticated cyber actors and nation-states exploit vulnerabilities to steal information and money and are developing capabilities to disrupt, destroy or threaten the delivery of essential services such as drinking water and wastewater. As with any critical enterprise or corporation, drinking water and wastewater utilities must evaluate and mitigate their vulnerability to a cyber incident and minimize impacts in the event of a successful attack.

Cyber incidents can compromise the ability of water and wastewater utilities to provide clean and safe water to customers, erode customer confidence and result in financial and legal liabilities. The following sections outline actions drinking water and wastewater utilities can take to prepare for, and respond to, cyber incidents.

Indicators: Can include:

- a) Loss of ability to access or use SCADA system.
- b) Visible signs of SCADA network tampering.

Actions:

- 1) If possible, disconnect compromised computers from the network to isolate breached components and prevent further damage, such as the spreading of malware. Do not turn off or reboot systems – this preserves evidence and allows for an assessment to be performed.
- 2) Assess any damage to utility systems and equipment, along with disruptions to utility operations.

- 3) Notify utility personnel, take action to restore operations of mission critical processes (e.g., switch to manual operation if necessary), and public notification (if required).
- 4) Report the cyber incident as required to law enforcement and regulatory agencies.

7.2. IT and/or IT Contractor Steps

- 1) Notify any external entities (e.g., vendors, other government offices) that may have remote connections to the affected network(s).
- 2) Document key information on the incident, including any suspicious calls, emails, or messages before or during the incident, damage to utility systems, and steps taken in response to the incident (including dates and times).
- 3) Review system and network logs and use virus and malware scans to identify affected equipment, systems, accounts and networks.
- 4) Document which user accounts were or are logged on, which programs and processes were or are running, any remote connections to the affected IT systems or network(s) and all open ports and their associated applications. If possible, take a “forensic image” of the affected IT systems to preserve evidence. Tools to take forensic images include Forensic Tool Kit (FTK) and EnCase.
- 5) If possible, identify any malware used in the incident, any remote servers to which data may have been sent during the incident, and the origin of the incident. Canadian Centre for Cyber Security can assist. contact@cyber.gc.ca or [1-833-CYBER-88](tel:1-833-CYBER-88).
- 6) Research and identify if any employee or customer personally identifiable information (PII) was compromised.
- 7) Check the system back-up time stamp to determine if the back-up was compromised during the incident.
- 8) Document all findings and avoid modifying or deleting any data that might be attributable to the incident.

SECTION 8: Drought

8.1 Introduction

Drought is often caused by a long duration of inadequate rainfall or snowmelt to replenish the level of the water source. It can also be the result of a breakdown in a crucial piece of a water system's infrastructure; or a prolonged issue with water quality that prevents the supply of potable water for an extended period. All of these circumstances can result in a significant depletion in the source capacity or even a complete loss of source. The Cariboo Regional District's Drought Management Plan for the Russet Bluff Water System serves as a guide to monitoring, managing and conserving water use in the event of an impending drought. The objectives of this Plan are to:

- 1) Identify the priority users of the water supply.
- 2) Provide direction on water conservation before and during the drought period.
- 3) Establish a guideline for communicating issues and instructions to users and other key contacts.
- 4) List supplemental or alternate sources of potable water in the event of a prolonged drought.

Appendix C outlines the Cariboo Regional District's Drought Management Plan.

Appendix A: Contacts

Cariboo Regional District Administrative Staff Emergency Contact Numbers

Title	Contact	Work #	Cell #
Manager of Utilities	Kelly McDonald	(250) 305-2179	(250) 855-8340
Manager of Communications	Gerald Pinchbeck	(250) 392-3351 Ext. 213	(250) 305-7576
Manager of Emergency Programs	Irene Israel	(250) 392-3351 Ext. 274	
Chief Administrative Officer	Murray Daly	(250) 392-3351 Ext. 214	
Manager of Fire Administration	Cody Braaten	(250) 392-3351 Ext. 265	
Regional Fire Chief	Roger Hollander	(250) 392-3351 Ext. 204	
Environmental Services Assistant	Cheryl McMullen	(250) 392-3351 Ext. 250	

Cariboo Regional District Water Operators

Region	Operator	Work #	Cell #
Central (WL)	Ken Heidema	1-800-665-3456 (press 5 when prompted)	(250) 855-4097
Central (WL)	Chuck Howes		(250) 855-8563
South (100 Mile)	Jourdy Ouellette		(250) 945-5661
South (100 Mile)	Larry Perry		(250) 945-4756
South (100 Mile)	Colin Brusic		(250) 945-4312
North (Quesnel)	Tyler Olsen		(250) 255-7697
North (Quesnel)	Phil Wilkins		(250) 255-0910

Provincial and Federal Contacts

Organization	Contact	Work #	Emergency #
Interior Health	Christine Sweezey, Environmental Health Officer	(250) 302-3000	(250) 706-0571
Interior Health	MHO (after hours on-call)		1-866-457-5648
BC Environmental Emergency Branch	(Report a Spill)	(250) 398 4530	1-800-663-3456
BC Hydro (Electrical)	Office	1-888-769-3766	1-800-224-9376
Canadian Centre for Cyber Security		1-833-CYBER-88	
FortisBC (Gas)	Office	1-888-224-2710	1-800-663-9911
School District No. 27	Cheryl Lenardon, Superintendent	(250) 398-3800	
Williams Lake Fire Dept.	Chief	(250) 392-4321	911
Williams Lake RCMP	Office	(250) 392-6211	911

Russet Bluff Water System – 2025 Emergency Response and Contingency Plan

Contractors

Company	Contact	Work #	Cell #
Electrical and Instrumentation: MacKay Electric	1. Nathan MacKay 2. Colin	(250) 617-5505	(250) 302-1055 (250) 302-1051
Excavating / Plumbing: Curt Morben Contracting	Curt Morben	(250) 398-7534	(250) 267-2240
Chlorine Pumps: Smith Cameron Pumps	Alex, Chlorine Pump Technician		(604) 679-0340
Instrumentation and SCADA: Exceed Electrical Engineering	Adam Cook	(250) 434-9489	(250) 267-2895
Laboratory: ALS Environmental	Caitlin Fountain	(250) 372-3588	(250) 572-1458
Snow Removal: ILJ Ventures	Drew	(250) 392-0770	
Well Pump Installer: Big Country Pumps	Rob	(250) 296-4115	(250) 302-1334

Municipalities

Municipality	Contact	Work #	Cell #
Williams Lake	Patrick Mahood, Manager of Public Works	(250) 392-2311	(250) 392-0867
Williams Lake	Matt Sutherland	(250) 392-2311	(250) 392-0864
100 Mile House	100 Mile House Public Works	(250) 395-2434	
100 Mile House	Todd Conway, Director	(250) 395-2434	

Media (Communications Department Leads)

Name	Type	Contact	Work #
CFFM The Goat	Radio/Digital		(250) 392-6551
CBC Kamloops	Radio/Digital		(250) 374-6802
100 Mile Free Press	Newspaper/Digital		(250) 395-2219
Global News	Television		(778) 945-9399

Appendix B: Charts

Appendix C: Drought Management Plan

DROUGHT MANAGEMENT PLAN

Priority Users

The area served by the Russet Bluff Water System is comprised of an estimated 250 residents. In a drought situation, the provision of water will be prioritized as follows:

Priority Level	User	Comments
1	Residents	The CRD is obligated to provide water to the residents served by the Russet Bluff Water System for basic health and sanitation needs.

Water Restrictions and Conservation Measures

The following restrictions will be imposed and conservation measures recommended to Russet Bluff Water System users at various stages prior to and during a drought:

STAGE 1: PREPAREDNESS	
Permitted Uses	Restrictions
Drinking water Bathing Handwashing dishes or using dishwasher Washing machine Watering plants with a hose or watering can Bathing pets. Washing vehicles.	May 1 to Oct. 1: Lawn watering on reduced days for reduced hours, per bylaws.
	Conservation Measures
	Install water-saving devices.
STAGE 2: IMPENDING DROUGHT – CONSERVATION	
Permitted Uses	Restrictions
Drinking water Bathing Handwashing dishes or using dishwasher Washing machine Watering plants with a hose or watering can	Lawn watering days and hours restricted further. Wash vehicles only if absolutely necessary.
	Conservation Measures
	Bathe pets only as needed. Use washing machine for full loads only. Use dishwasher for full loads only.
STAGE 3: DROUGHT – RESTRICTIONS	
Permitted Uses	Restrictions
Drinking water (all users) Bathing Handwashing dishes or using dishwasher Washing machine	No watering of lawns or watering of plants, per bylaws. No bathing of pets unless absolutely necessary. No washing of vehicles. No filling of swimming pools. No power-washing.
	Conservation Measures
	Bathe only as needed and/or reduce time in shower. Use washing machine for full loads only. Use dishwasher for full loads only.

Communication Plan

Communication between the CRD and users of the Russet Bluff Water System, as well as with key operational contacts, is imperative during an emergency situation. Providing timely and clear

Russet Bluff Water System – 2025 Emergency Response and Contingency Plan

information and instructions greatly reduces confusion, frustration and anxiety, and enables outside agencies to provide assistance more effectively if needed.

STAGE 1: PREPAREDNESS		
Water use is routinely higher from mid-Spring to the end of Summer each year due to less rainfall, increased lawn and garden maintenance, swimming pools, more frequent car-washing and showers, etc. Water levels are constantly monitored, and watering restrictions are put in place annually from May 1 to October 1 as a preventative measure to minimize depletion of the water supply during these months.		
Procedures (Concurrent)		Target
Finance Dept. mails notice of water restrictions and water conservation recommendations with annual utility bills in April of each year.		Residents
Communications Dept. posts notice of water restrictions and water conservation recommendations on website and social media.		All users of the Russet Bluff Water System
Communications Dept. sends notice of water restrictions and water conservation recommendations by email.		Subscribed users.
Water Operators post notice of water restrictions and water conservation recommendations on bulletin boards at 108 Mall, gas station, mailboxes		Users of the Russet Bluff Water System who don't have access to a computer.
STAGE 2: POTENTIAL THREAT – DIMINISHED WATER SUPPLY		
If there is little snowmelt in the Spring and rainfall in the Spring/Summer is not enough to bring the source of the water supply to an adequate level, further restrictions on water use may be required. Prolonged water quality issues may result in having to obtain water from an alternate source until rectified. Any significant or ongoing issues would indicate that action is required to prevent the possibility of a water supply crisis.		
Procedures		Target
1.	Inform key contacts of possible threat to water source: Water Operators notify Manager of Utilities Manager of Utilities informs other key contacts	Manager of Utilities Drinking Water Officer Electoral Area Director Manager of Fire Administration
2.	At Interior Health's direction, Manager of Utilities and Communications Dept. have public notice mailed to users, posted on website, social media, and on local bulletin boards.	All users of the Russet Bluff Water System
	Communications Dept. sends public notice by email.	Subscribed users
3.	Manager of Utilities notifies CRD Managers involved in Emergency Planning as a precautionary measure.	Chief Administrative Officer Manager of Communications Manager of Emergency Programs
4.	Manager of Utilities, Water Operators and Electoral Area Director hold public meeting to discuss potential drought, further restrictions required and recommended conservation measures.	All users of the Russet Bluff Water System
5.	Manager of Utilities notifies other agencies as a precautionary measure that assistance may be required if situation can't be rectified.	City of Williams Lake Ministry of Water, Land and Resource Stewardship Ministry of Emergency Management and Climate Readiness

Russet Bluff Water System – 2025 Emergency Response and Contingency Plan

STAGE 3: EMERGENCY – SIGNIFICANT DEPLETION OR LACK OF SOURCE	
<p>The following situations are considered critical:</p> <ul style="list-style-type: none"> • An inability to keep the water supply at a level that will provide enough water to meet the basic health and sanitation needs of the users. • A prolonged issue with the water system infrastructure that results in the inability to provide water to the users. • A severe or prolonged water quality issue that cannot be easily rectified. • The inability to provide an adequate water supply for fire protection. • An ongoing water supply issue that results in significant losses for businesses in the service area. 	
Procedures	Target
1. Inform key contacts of crisis situation. Discuss further steps: Water Operators inform Manager of Utilities. Manager of Utilities notifies other key contacts.	Manager of Utilities Drinking Water Officer Electoral Area Director Chief Administrative Officer Manager of Fire Administration Manager of Communications Manager of Emergency Programs
2. At Interior Health’s direction, Manager of Utilities and Communications Dept. have public notice mailed to users, and posted on website, social media, and local bulletin boards.	All users of the Russet Bluff Water System
Communications Dept. sends notice of emergency situation by email and via Voyent Alert.	Subscribed users
3. Manager of Utilities and Communications Dept. post notice in local newspaper; make radio announcements.	All users of the Russet Bluff Water System
4. Manager of Utilities, Water Operators and Electoral Area Director hold public meeting to discuss further steps.	All users of the Russet Bluff Water System
5. Manager of Utilities notifies other agencies. Discuss what assistance may be available.	City of Williams Lake Ministry of Water, Land and Resource Stewardship Ministry of Emergency Management and Climate Readiness

Supplemental or Alternate Sources of Potable Water

Supplemental or Alternate Source	Contact Information	Capacity Available	Estimated Time To Deliver	Estimated Cost
Backup Water Source				
Reservoir Rental Company				
Bulk Haul Water	Triple P Sanitation (upon verification of IH permit)	Not specified	Pick up only	\$100 upon opening a/c, plus \$0.15 per litre
	Triple P Sanitation (upon verification of IH permit)	Not specified		
Other Water Supplier	Triple P Sanitation (upon verification of IH permit)	Not specified		

Russet Bluff Water System – 2025 Emergency Response and Contingency Plan

Supplemental or Alternate Source	Contact Information	Capacity Available	Estimated Time To Deliver	Estimated Cost
Bottled Water	Cariboo Water Purification Centre	Not specified	Tuesdays	\$6.50 / 5 Gal \$4.00 / 3 Gal
	Cool Clear Water	Not specified		
	Williams Lake Water Factory	Not specified		

Operational Procedures

Action		Person Responsible
1	Ensure pump is shut off (to protect pump).	Water Operator
2	Notify all users by social media, email distribution, radio and public bulletins. High risk users to be notified by telephone call. Situationally assessed for best means of communication process.	Manager of Utilities Manager of Communications
3	Contact government agencies (see below) for advice and assistance.	Manager of Utilities
4	Arrange alternate source (e.g. bottled water, bulk hauler and storage tank).	Manager of Utilities
<p>Government Agency Contacts:</p> <ul style="list-style-type: none"> • Drinking Water Officer • Local government's Emergency Program Coordinator • Ministry of Forests, Lands and Natural Resource Operations • Others as necessary, depending on severity (ie. Fire Department) 		

Appendix D: Templates

Damage Assessment Summary (EOC 415)

DAMAGE ASSESSMENT SUMMARY				
	Event:	Time:		Date:
	Operational Period:	PEP Task #:		Position:
		Number	Estimated Value	Comments
Public Property	▪ Municipal Facilities Damaged			
	▪ Municipal Facilities Destroyed			
	▪ Public Facilities Damaged			
	▪ Public Facilities Destroyed			
	▪ Provincial Facilities Damaged			
	▪ Provincial Facilities Destroyed			
	▪ Federal Facilities Damaged			
	▪ Federal Facilities Destroyed			
	▪ Roads Damaged			
	▪ Roads Destroyed			
	▪ Bridges Damaged			
	▪ Bridges Destroyed			
	▪ Railroads Damaged			
	▪ Railroads Destroyed			
	▪ Water Supply Damaged			
	▪ Sewers Damaged			
	Total Public Damage:			
	Private Property	▪ Residential Buildings Damaged		
▪ Residential Buildings Destroyed				
▪ Businesses Damaged				
▪ Businesses Destroyed				
▪ Agriculture Damaged				
▪ Agriculture Destroyed				
Total Public Damage:				
Priority Repairs/Restoration:				
Prepared By:			Date and Time:	

Action Plan (EOC 502)

EOC ACTION PLAN					
Event:		Date:		Time:	
Operational Period:		PEP Task #:		Prepared By:	
Objectives: (In priority order, for the designated operational period)					
Tasks/Action Items:				Function Assigned	Estimated Completion Time
Attachments: (Check if attached)					
<input type="checkbox"/>	Organization Chart	<input type="checkbox"/>	Public Information Plan	<input type="checkbox"/>	Communication Plan
<input type="checkbox"/>	EOC Floor Plan	<input type="checkbox"/>	Transportation Plan	<input type="checkbox"/>	
<input type="checkbox"/>	Situation Map	<input type="checkbox"/>	Evacuation Plan	<input type="checkbox"/>	
Recommended By (Planning Section Chief):			Approved By (EOC Director):		

- Distribution:**
- | | |
|--|--|
| <input type="checkbox"/> EOC Director
<input type="checkbox"/> Risk Management Officer
<input type="checkbox"/> Liaison Officer
<input type="checkbox"/> Information Officer
<input type="checkbox"/> Posted for ALL EOC Personnel | <input type="checkbox"/> Operation Section Chief
<input type="checkbox"/> Planning Section Chief
<input type="checkbox"/> Logistics Section Chief
<input type="checkbox"/> Finance/Administration Section Chief
<input type="checkbox"/> Other _____ |
|--|--|

Situation Report (EOC 501)

EOC SITUATION REPORT

Community / Local Authority: _____

Date and Time: _____

PEP Task Number: _____

Prepared By: Community / Local Authority
 PREOC Operational Area Coordinator

Approved By: _____
(Name and Position)

<p>EOC Contact: Name: _____ Position: _____ _____ Phone #: _____ Fax #: _____ E-mail: _____</p>	<p>Report Type: <input type="checkbox"/> Initial <input type="checkbox"/> Update # _____ <input type="checkbox"/> Final</p> <p>Situation Forecast: <input type="checkbox"/> Improving <input type="checkbox"/> Unchanged <input type="checkbox"/> Deteriorating</p>
--	---

Highlights *(Situational Overview – Key Points):*

Current Priority Needs: *(Resources / Information / Support):*

Resource Request Attached: Yes No

People Impacted *(Estimated / Confirmed):*

# Evacuated	# Injured	# Homeless*	# Missing	# Dead	# Hospitalized

* As a result of the emergency event

Event Log (EOC 414)

POSITION LOG						
Event:	Section:	Position:				
Operational Period:	PEP Task #:	Date:				
LOG						
Time (24 Hr.)	To	From	Action	Follow-Up	Closed	

Appendix E: Communications Templates



The Cariboo Regional District has issued a Boil Water Notice to users of the **{SYSTEM NAME}** Water System, pursuant to a request of a Drinking Water Officer under Section 14 of the *Drinking Water Protection Act*. This Notice remains in effect until further notice.

The Cariboo Regional District's water systems are tested regularly to ensure they meet public health regulations. This boil water notice is being issued because **{REASON}**. This notice is being issued **{CHOOSE: as a precautionary measure to protect public health. OR in order to protect public health and safety from significant health risks presented by pathogens in the water supply.}**


All users of the **{WATER SYSTEM NAME}** Water System are asked to bring water to a rolling boil for a minimum of one minute before using water from the system for:

- Drinking (or use an alternate, safe source of water)
- Cooking (if not boiled)
- Brushing teeth
- Washing Dishes
- Washing fruits or vegetables to be eaten raw
- Watering animals

Also, please use hand sanitizer after washing hands.

If you have further questions, please call Environmental Services at 1-800-665-1636 during regular office hours.

For more information about boil water advisories and service interruptions in the CRD and what to expect, visit cariboord.ca/water-notices-and-advisories. To receive updates on CRD water systems and other relevant information within the CRD, residents are reminded to subscribe to the latest news on our website at cariboord.ca/subscribe. Residents can also sign up the Cariboo Chilcotin Emergency Notification System to be notified directly of emergency orders and alerts or utility service interruptions at cariboord.ca/EmergencyNotifications.



The Cariboo Regional District has issued a Do Not Use Notice to users of the **{SYSTEM NAME}** Water System, pursuant to a request of a Drinking Water Officer under Section 14 of the *Drinking Water Protection Act*. This Notice remains in effect until further notice.

The Cariboo Regional District's water systems are tested regularly to ensure they meet public health regulations. Due to the presence of {if known, be specific, or if unknown say "contaminants in the water supply posing an immediate threat to resident's safety"}, the Cariboo Regional District is implementing this until further notice. Follow all instructions below:

All users of the **{WATER SYSTEM NAME}** Water System are asked to immediately stop using water from the system for any purpose. This includes: drinking, making beverages or ice, brushing teeth, preparing or washing food, bathing, water for animals, washing anything (including vehicles), and watering plants.

Do not turn your taps on for any reason. Boiling water will NOT make it safe! Water from your hot water tank may also be unsafe, and you are advised to consult a qualified plumber before draining the tank.


The Cariboo Regional District has contacted Interior Health and the Ministry of Environment to request their cooperation in investigating this matter. In addition, the Cariboo Regional District is taking immediate action to find another source of water supply for residents of **{WATER SYSTEM NAME}**.

During this time, an alternate water source will be available at **{ADDRESS AND OPERATING HOURS}**.

If you have further questions, please call Environmental Services at 1-800-665-1636 during regular office hours.

For more information about boil water advisories and service interruptions in the CRD and what to expect, visit cariboord.ca/water-notices-and-advisories. To receive updates on CRD water systems and other relevant information within the CRD, residents are reminded to subscribe to the latest news on our website at cariboord.ca/subscribe. Residents can also sign up the Cariboo Chilcotin Emergency Notification System to be notified directly of emergency orders and alerts or utility service interruptions at cariboord.ca/EmergencyNotifications.

 @CaribooRD cariboord.ca facebook.com/caribooregion  facebook.com/CRDEmergencyOperations



The image shows a public notice template for a water quality advisory. At the top left is the Cariboo Regional District logo, which features a stylized moose head and the text "Cariboo Regional District". To the right of the logo, the words "PUBLIC NOTICE" are written in large, bold, white capital letters on a dark blue background. Below this, a photograph of hands filling a glass of water from a tap is shown. Overlaid on the photo is the text "WATER QUALITY ADVISORY" in blue, followed by "{SYSTEM NAME} Water System" in black, and "Effective {DATE}" in black. Below the photo, there are three paragraphs of text. The first paragraph states that the Cariboo Regional District has issued a water quality advisory to the {SYSTEM NAME} Water System users because of {issue} levels exceeding the Guidelines for Canadian Drinking Water Quality. The second paragraph explains that the district's water systems are tested regularly and that recent samples show {issue} concentrations that exceed the MAC. The third paragraph is a placeholder for information provided by Health Canada or Interior Health, with a yellow highlight and a note that this section requires approval from a Drinking Water Officer. Below this is another placeholder for other safety instructions. The bottom of the notice includes contact information for the Environmental Services department and a link to the district's website for more information. At the very bottom, there is a dark blue footer bar with social media icons and links for Twitter (@CaribooRD), the website (cariboord.ca), and Facebook (facebook.com/caribooregion and facebook.com/CRDEmergencyOperations).

Cariboo Regional District

PUBLIC NOTICE

WATER QUALITY ADVISORY
{SYSTEM NAME} Water System
Effective {DATE}

The Cariboo Regional District has issued a water quality advisory, to the {SYSTEM NAME} Water System users because of {issue} levels exceeding the *Guidelines for Canadian Drinking Water Quality*. This Advisory remains in effect until further notice.

The Cariboo Regional District's water systems are tested regularly to ensure they meet public health regulations. Health Canada's Guidelines for Drinking Water has established a maximum acceptable concentration (MAC) for {issue} in drinking water of {standard}. Recent water samples submitted show {issue} concentrations that exceed the MAC.

Add information provided by Health Canada or Interior Health about the nature of the water quality advisory. This section requires approval from a Drinking Water Officer.

{Other safety instructions or advisories. I.e. is the water safe for other non-consumption purposes, how does boiling water impact it, etc.}

If you have further questions, please call the Environmental Services department at 1-800-665-1636 during regular office hours.

For more information about boil water advisories and service interruptions in the CRD and what to expect, visit cariboord.ca/water-notices-and-advisories. To receive updates on CRD water systems and other relevant

@CaribooRD cariboord.ca facebook.com/caribooregion facebook.com/CRDEmergencyOperations

Cariboo Regional District

PUBLIC NOTICE

WATER QUALITY ADVISORY
{SYSTEM NAME} Water System
Effective {DATE}

The Cariboo Regional District has issued a water quality advisory, to the {SYSTEM NAME} Water System users because of manganese (Mn) levels exceeding the *Guidelines for Canadian Drinking Water Quality*. This Advisory remains in effect until further notice.

The Cariboo Regional District's water systems are tested regularly to ensure they meet public health regulations. Health Canada has established a maximum acceptable concentration (MAC) for manganese in drinking water of 0.12 mg/L. Recent water samples submitted show manganese concentrations that exceed the MAC.

Manganese (Mn) is an element found in air, food, soil and drinking water. While a small amount of Mn is essential for human health, new Health Canada research has shown drinking water with too much Mn can be a risk to health for infants and young children.

Infants and young children are the most sensitive and vulnerable population, as their bodies absorb more manganese and cannot regulate or remove the chemical as readily as adults and older children. As a result, the drinking water from this system must not be used to prepare formula for bottle-fed infants. An alternate source of safe drinking water, such as bottled water, must be used when preparing formula for infants and young children. **Boiling the water will not lower the manganese level.**

Breastfed infants are generally considered at lower risk to manganese exposure as the transfer of manganese to breast milk is limited. Pregnant or breastfeeding women who have concerns may wish to use a safe, alternate source of drinking water or consult with a healthcare professional.

Water exceeding the MAC for manganese can be used for cooking and drinking by non-vulnerable groups and is still considered safe for hand washing, bathing and showering. If you have further questions, please call the Environmental Services department at 1-800-665-1636 during regular office hours.

For more information about boil water advisories and service interruptions in the CRD and what to expect, visit cariboord.ca/water-notices-and-advisories. To receive updates on CRD water systems and other relevant information within the CRD, residents are reminded to subscribe to the latest news on our website at cariboord.ca/subscribe.

@CaribooRD cariboord.ca facebook.com/caribooregion facebook.com/CRDEmergencyOperations



The Cariboo Regional District has issued a water quality advisory for users of the Forest Grove Water System because of a positive test result for low coliform found in the system.

For this reason, as precautionary measure, any high-risk users, including those with weakened immune systems, young children and those on dialysis are advised to:

- use purchased bottled water or boiled water for drinking, brushing teeth, dishwashing, preparing food, and making ice, or
- bring water to a roiling boil for one minute, then cool to an appropriate temperature before using.

The CRD regularly tests the water system as part of its Water Quality Monitoring Program. The advisory will remain in effect until further notice. We apologize in advance for any inconvenience this may cause.

When satisfactory results are reported from the required testing, customers will be notified that the advisory has been lifted. If you have questions, please call the Environmental Services department at 1-800-665-1636. If calling outside of regular business hours (8:30 a.m. to 4:30 p.m. Monday to Friday), please dial "5" when prompted to reach our emergency after hours contact.

For more information about boil water advisories and service interruptions in the CRD and what to expect, visit cariboord.ca/water-notices-and-advisories.

To receive updates on CRD water systems and other relevant information within the CRD, residents are reminded to subscribe to the latest news on our website at cariboord.ca/subscribe.

 @CaribooRD cariboord.ca facebook.com/caribooregion  facebook.com/CRDEmergencyOperations